

GOVERNMENT OF GUAM
DEPARTMENT OF PUBLIC HEALTH AND SOCIAL SERVICES
DIVISION OF ENVIRONMENTAL HEALTH
PUBLIC SWIMMING POOL INSPECTION REPORT

ESTABLISHMENT NAME NORTHERN REGION RECREATIONAL POOL	LOCATION HARMON LOOP, DEDEDO, GUAM	
INSPECTION DATE 01 / 31 / 2020	SANITARY PERMIT NO. 190003154	PERMIT HOLDER GOVSUAM DEPT. OF PARKS & RECREATION

Based on this inspection, the items listed below identify violations which shall be corrected within the time frames indicated, or as stated in Title 10 Guam Code Annotated, Chapter 21, Section 21107. Failure to comply with any notice issued in accordance with the provisions of the applicable rules or regulations may result in immediate suspension of the Sanitary Permit or downgrade. If seeking to appeal the result of this inspection, a written request for hearing must be submitted to the Director within the period of time established in the notice of corrections.

Inspection Results
OUT = Out of compliance R = Repeat violation COS = Corrected On Site

Item #	Correct by date	Description of Violation	Compliance Status
--------	-----------------	--------------------------	-------------------

AN ASSESSMENT WAS CONDUCTED TODAY IN RESPONSE TO COMPLAINT NO. 20-018A, REGARDING THE SWIMMING POOL BEING DIRTY. THE COMPLAINT WAS OBSERVED DURING THIS INSPECTION; THE POOL WATER WAS FOUND TO BE MURKY AND GREENISH IN COLOR.

ACCORDING TO THE DIRECTOR OF THE DEPARTMENT OF PARKS AND RECREATION, THE POOL WAS "SHOCKED" (THAT IS, SUPERCHLORINATED) LAST NIGHT AND THEY PLANNED TO VACUUM THE DIRT/DEBRIS FROM THE POOL TODAY; THUS, THEY HAD CLOSED THE FACILITY TO THE PUBLIC.

PER OPERATOR, THE BACKWASH ^{CONTROLER} ~~SYSTEM~~ ^{SYSTEM} FOR THE FILTRATION, HAS BEEN DOWN SINCE APRIL 2018 NO MAINTENANCE / CHEMICAL RECORDS WERE AVAILABLE ON SITE. THE OPERATOR SAID THAT HE KEEPS THEM ON A FLASH DRIVE AND WILL SEND THEM TO DPSS VIA EMAIL.

THE FOLLOWING WATER QUALITY READINGS WERE TAKEN BY THE OPERATOR DURING THIS INSPECTION:

FREE CHLORINE - 7.5
pH - 7.4

THE OPERATOR VOLUNTARILY AGREED TO CEASE OPERATION OF THE SWIMMING POOL & THE FACILITY SHALL REMAIN CLOSED UNTIL PRIOR APPROVAL FROM DPSS IS OBTAINED. PHOTOS WERE TAKEN.

BRIEFED CERTIFIED POOL OPERATOR, NICOLAS JUDE QUINATA, ON ABOVE.

Person in Charge (Print Name and Sign) Nicolas Quinata	Date 01 / 31 / 2020
DEH Inspector (Print Name and Sign) LEILANI NAVARRO & JEROME GARCIA	Date 01 / 31 / 2020